

# SUBMITTAL PACKAGE

## SPLIT-SYSTEM CONDENSING UNITS

PROJECT: \_\_\_\_\_ LOCATION: \_\_\_\_\_ DATE: \_\_\_\_\_

PURCHASER: \_\_\_\_\_

ARCHITECT: \_\_\_\_\_ ENGINEER: \_\_\_\_\_

PO#: \_\_\_\_\_ FOR REFERENCE: \_\_\_\_\_

SUBMITTED BY: \_\_\_\_\_ FOR APPROVAL: \_\_\_\_\_

### 10.9 SEER Condensing Units

ALL MODELS ARE RATED 208-230/1/60

PLAN DESIGNATION	MODEL	QUANTITY	RATED COOLING/HEATING OUTPUTS (B/HR)	MINIMUM AWG WIRE	MAXIMUM FUSE
	NCPC018-1010		18,000 BTU	14	15
	NCPC024-1010		23,900 BTU	12	20
	NCPC030-1010		28,500 BTU	12	25
	NCPC018-3010		18,000 BTU	14	15
	NCPC024-3010		23,800 BTU	12	20
	NCPC030-3010		29,500 BTU	12	25
	NCPC018-4010		18,000 BTU	14	15
<b>OUT OF STOCK</b>	NCPC024-4010		23,600 BTU	12	20
	NCPC030-4010		28,500 BTU	12	25

### Accessories/Options

QUANTITY	PART NO.	DESCRIPTION
	14269019 (1000 Series)	Architectural Louver Grille (non-painted)
	14269020 (3000 Series)	Architectural Louver Grille (non-painted)
	14269021 (4000 Series)	Architectural Louver Grille (non-painted)
	14269019-P (1000 Series)	Architectural Louver Grille (painted)
	14269020-P (3000 Series)	Architectural Louver Grille (painted)
	14269021-P (4000 Series)	Architectural Louver Grille (painted)
	1000WS	Wall Sleeve
	3000WS	Wall Sleeve
	4000WS	Wall Sleeve



HEATING & AIR CONDITIONING EQUIPMENT

A Division of National Refrigeration & Air Conditioning Products, Inc.

539 Dunksferry Road • Bensalem, PA 19020 • (215) 244-1400 • 1-800-523-7138 • Fax: (215) 639-1674