

SUBMITTAL PACKAGE

SPLIT-SYSTEM CONDENSING UNITS



MEETS 2010 DOE REQUIREMENTS FOR ALL UNITS.

PROJECT: _____ LOCATION: _____ DATE: _____

PURCHASER: _____

ARCHITECT: _____ ENGINEER: _____

PO#: _____ FOR REFERENCE: _____

SUBMITTED BY: _____ FOR APPROVAL: _____

12.0 SEER Condensing Units

ALL MODELS ARE RATED 208-230/1/60

PLAN DESIGNATION	MODEL	QUANTITY	RATED COOLING/HEATING OUTPUTS (B/HR)	MINIMUM AWG WIRE	MAXIMUM FUSE
	NCPC418-1010		18,000 BTU	14	15
	NCPC424-1010		23,900 BTU	12	20
	NCPC418-3010		18,000 BTU	14	15
	NCPC424-3010		23,800 BTU	12	20
	NCPC418-4010		18,000 BTU	14	15
	NCPC424-4010		23,600 BTU	12	20

Accessories/Options

QUANTITY	PART NO.	DESCRIPTION
	14269019 (1000 Series)	Architectural Louver Grille (non-painted)
	14269020 (3000 Series)	Architectural Louver Grille (non-painted)
	14269021 (4000 Series)	Architectural Louver Grille (non-painted)
	14269019-P (1000 Series)	Architectural Louver Grille (painted)
	14269020-P (3000 Series)	Architectural Louver Grille (painted)
	14269021-P (4000 Series)	Architectural Louver Grille (painted)
	1000WS	Wall Sleeve
	3000WS	Wall Sleeve
	4000WS	Wall Sleeve



HEATING & AIR CONDITIONING EQUIPMENT

A Division of National Refrigeration & Air Conditioning Products, Inc.

539 Dunksferry Road • Bensalem, PA 19020 • (215) 244-1400 • 1-800-523-7138 • Fax: (215) 639-1674